

TERRAPIN

ARCHITECTURE ^{PC}

Richard Berg, Architect Eric Kuzma, Architect AIA

December 9, 2011

Port of Port Townsend
Tenant Improvement for:
CBP OFFICE
375 Hudson Street
Port Townsend, WA 98368

ADDENDUM 3

1. CONSTRUCTION DOCUMENTS, SHEET A3.1: **Construction Notes:** Note #1 should read: "The floor in this room is to be Marmoleum over 1/4" AC Plywood, over 1/2" concrete tile backer board, over 9 gauge diamond mesh, over the existing aluminum vapor barrier membrane.